

Fire Lanes and Access Roads



Fire access roads need to be a minimum of 20' in width. To prevent parking in the fire access road, signage on the curb or signs posted along the road are required. If an access road is 26' or more, parking is allowed on one side and if the access road is 32' or more, parking is allowed on both sides. Any access road less than 26' will not allow parking on either side.

Supporting Documents

 [Fire Lane Drawing](#)

Source URL (retrieved on 12/13/2017 - 6:49am): <http://ci.oswego.or.us/fire/fire-lanes-and-access-roads>