



**NOTES:**

1. CONTRACTION JOINTS (1 1/2" DEEP) SHALL BE PLACED AT ALL WEEP HOLES, CHANGES OF DIRECTION, POINTS OF CURVATURE AND AT A MAXIMUM SPACING OF 10 FEET.
2. CONCRETE USED FOR CURB AND GUTTER SHALL MEET A 3,000 PSI COMPRESSION STRENGTH AT 28 DAYS.
3. IF ROOF DRAIN IS EXISTING, REPLACE WITH A 3" SCH. 40 PVC PIPE WITH A BELL, OR 3" EXTENSION.
4. FINISH ENTIRE CONCRETE SURFACES TO SMOOTH AND UNIFORM TEXTURE WITH BROOM FINISH, UNLESS OTHERWISE DIRECTED.



City of Lake Oswego  
Engineering Division

Erica Rooney, P.E. City Engineer

**STANDARD CURB AND  
GUTTER DETAIL**

**S2-02**

EFFECTIVE DATE: JANUARY 1, 2018

NOT TO SCALE

DRAWING NUMBER