



Notes:

- 1) Knife joints shall be placed at all weep holes, changes of direction, points of curvature and at a maximum spacing of 20 feet.
- 2) Concrete used for curb and gutter shall meet a 4,000 p.s.i. compression strength at 28 days.
- 3) 3" plastic pipe shall have a bell or a 3" extension for future hook-up.



City of Lake Oswego
Engineering Division

Guy Graham, P.E. Public Works Director
City Engineer

STANDARD CURB AND
GUTTER DETAIL

DRAWING NUMBER: S2-02

Drawn: DB	Redrawn:
Design: JBK	Redesigned:
Checked: JBK	Update: KBK
Scale: N.T.S.	Update Check: DK
Date: 4-26-05	Date/Update: 10/15/12