


Notes: 1. For new manhole construction, use 1/2" thick HDPE partition. For retrofitting, when the cone will not be removed, use 1/4" thick hdpe partition. 2. Partition width may vary depending on manhole conditions. When retrofitting, contractor shall build to appropriate dimensions.



City of Lake Oswego
Engineering Division
Guy Graham, P.E. Public Works Director
City Engineer

INSIDE DROP MANHOLE

DRAWING NUMBER: SD1-06

Drawn: DB	Redrawn:
Design: U.S.A.	Redesigned:
Checked: MS	Update: KBK
Scale: N.T.S.	Update Check: DK
Date: 6/17/98	Date/Update: 3/14/12