



- NOTES:**
- 1) ALL PRECAST SECTIONS SHALL CONFORM TO THE REQUIREMENTS OF A ASTM-C-478. ALL POURED IN PLACE CONCRETE SHALL HAVE A 28 DAY STRENGTH OF 3,000 P.S.I..
 - 2) ELEV. OF BASE, I.E., & OVERFLOW SHALL BE APPROVED BY CITY.
 - 3) SEE CITY STD. DETAIL SD1-03B FOR ELBOW, LIFT HANDLE, SHEAR GATE DETAILS & NOTES.