



3/4" galvanized rigid conduit, 4' minimum length from termination to weatherproof box. 3-piece couplings at box are acceptable when threads are treated with never-seize.

NOTES

- 1) For use in planter beds only
- 2) Horizontal distance to sidewalk min. 2 ft.
- 3) Location to be approved prior to install



City of Lake Oswego
Engineering Division

Guy Graham, P.E. Public Works Director
City Engineer

TYPICAL ABOVE-GROUND
POWER RECEPTACLE

DRAWING NUMBER: S10-01

Drawn: KBK	Redrawn:
Design:	Redesigned:
Checked: DK	Update: NA
Scale: N.T.S.	Update Check: NA
Date: 01/08/14	Date/Update: NA